

BUB/CTE/2014-15

DATE: 04-04-2015

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (28 days Compressive Strength)

{Project*:Improvements to roads and Construction of drains at Kempegowda
Layout (next to RR school) in Ward No.10, of Vidyaranyapure Sub-Division}

Ref.: Letter No. Testing/BUB/2014-15, dated 01-04-2015

Sample supplied to lab by: , : Sri.Aswathnarayana Anjanappa, Contractor,
Bangalore.

Report required for: Assistant Executive Engineer,
Vidyaranyapure Sub-Division.
BBMP, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1 :

Sl No	Location/ Identification *	Date of Casting*	Date of Testing	Age in Days	C/S Area in Mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	04-03-15	01-04-15	28	22500	520	22.88	23.03
	002	"	"	"	"	525	23.33	
	003	"	"	"	"	520	22.88	

*As furnished by Client.

The Results relate only to the items tested.

Page No. 1/1,

G.R. HARISH

Professor

Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L

ME (Civil Engg) Ph D MISTE.MIRC

Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail: manjeshl@yahoo.com

BANGALORE UNIVERSITY

DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2014-15/

DATE: 04-04-2015

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (28days Compressive Strength)

{Project*: Improvements to Roads and Construction of drains at Kempegowda Layout (next to RR School) in Ward No.10 of Vidyanarayapura Sub-Division}

Ref: Letter No. Testing/BUB/2014-15, dated 01-04-2015

Sample supplied to lab by: Sri.Ashwathnarayana Anjanappa, Contractor.

Report required for: Assistant Executive Engineer,
Vidyanarayapura Sub-Division.
BBMP, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in Mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	04-03-15	01-04-15	28	22500	495	22.00	22.22
	002	"	"	"	"	510	22.66	
	003	"	"	"	"	495	22.00	

*As Furnished by Client.

The Results relate only to the items tested.



Page No. 1/1,

Manjesh L
Dr. MANJESH L
ME(Civil Engg.) Ph.D., MISTE, MIRC,
Associate Professor
Department of Civil Engineering
Bangalore University, Jnanabharathi Campus,
BANGALORE 560 056.
E-mail: manieshl@yahoo.com